Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 59 Dated: 10/09/2026

It is certified that an inspection team headed by ANIL KUMAR (CHEMIST)

(Name of Officers with designation) from DLWTL, P.H. DIVISION BETTIAHPHED

inspected the FRIENDS ACADEMY, BARWA BANJARIYA, RAMNAGAR, W. CHAMPARAN, BIHAR

(Name & Address of the school) on 09/09/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 58 dated 09/09/2026

of DLWTL, P.H. DIVISION BETTIAH (PHED Lab) certified that the

FRIENDS ACADEMY (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 09/09/2027

Signature with Seal: Anil 10/09/2026 CHEMIST DLWTL P.H. Division, Bettiah

Name : ANIL KUMAR

Designation : CHEMIST

Name & Address of the Office / Department : DLWTL P.H. DIVISION, BETTIAH

To FRIENDS ACADEMY
BARWA BANJARIYA, RAMNAGAR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

District Level Water Testing Laboratory P.H.Division, Bettiah

PUBLIC HEALTH DIVISION, BETTIAH

CHEMICAL & BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER SAMPLES

SAMPLE COLLECTED ON---07/09/2026 BY Mr. Pulkit Kumar & RECEIVED IN THE LABORATORY ON---07/09/2026

Sl. NO	PARTICULARS OF THE SAMPLE				PARAMETERS EXAMINED (VALUE IN Mg/L except pH. Otherwise Mentioned)														
	Block	Gram Panchayat	Village/ Ward Number	Name of the Nearest person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkanity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Flouride	T.D.S	Arsenic	Bacteriological test
18.	Ram Nagar	Sonkar	Barwa Banjariya	FRIENDS ACADEMY	0.99	7.3	379	154	162	36	12	23	15	<0.2	<1	0.3	253	NT	Neg.
Min-Max Permissible Limit (IS:10500/2012)					1-5 NTU	6.5 8.5	-	200 600	200 600	75 200	30 100	250 1000	200 400	1.0 NR	45 NR	1 1.5	500 2000	0.01 NR	+VE -VE

Remarks-- Analysed parameters of above sample is within permissible limit.

Memo No. 58, Dated: 09.09.2026

Anil Kr. 09/09/2026

Signature of the Chemist

CHEMIST
DLWTL
P.H. Division, Bettiah